

PROCUREMENT DEPARTMENT
Rm 120 Municipal Services Building
Philadelphia, PA 19102-1685
FAX: (215) 686-4716

CITY OF PHILADELPHIA

Mary E. Stitt
Procurement Commissioner

July 10, 2015

BID NUMBER: S6OO3070
TITLE: Pipe Fittings
DEPARTMENT: WATER DEPARTMENT-HUMAN RESOURCES DIVISION
DATE TO OPEN: June 26, 2015 at 10:30 AM

ADDENDUM # 2

TO ALL BIDDERS:

You are hereby notified of the following changes to the above mentioned bid:

The subject bid is now scheduled to open on August 03, 2015 at 10:30 AM

Please refer to attached Questions and Responses for subject Bid No. S6OO3070.

Question #1

Page 39, Item 5.22: Mechanical Joint Ductile Iron Retainer Glands

Are these Mega Logs?

Response:

Yes, they are Mega logs.

Question #2

Page 39, Item 5.23: PWD Bend Bands w/ special Restraining Mechanism and Accessories (2 Bolts & Nuts)

What are these accessories?

Response:

They are bolts, nuts and gaskets.

Question #3

Page 40, Item 5.24: Miscellaneous Ductile Iron Mechanical T-Bolt & Nut Connect / Fittings

What are the accessories in items 5.24.3 to 5.24.6 ?

Response:

They are T bolts and nuts.

Question #4


Page 41, Item 5.24.10

Is this a service saddle?

Response:

Yes, this is a service saddle.

Please sign, date and return this addendum with your bid to the Procurement Department, 1401 J.F.K Boulevard, Bid Room 170A, Philadelphia, PA 19102-1685 as it now becomes a part of the proposal.



J. Manton, Buyer

AUTHORIZED SIGNATURE

FIRM NAME (PRINT)

DATE

JM/dr

For JANICE MANTON