PROCUREMENT DEPARTMENT
Rm 120 Municipal Services Building
Philadelphia, PA 19102-1685
FAX: (215) 686-4716

CITY OF PHILADELPHIA

Mary E. Stitt
Procurement Commissioner

July 10, 2015

BID NUMBER: S6Z62190

TITLE: Boiler Service and Inspection,

DEPARTMENT: VARIOUS

DATE TO OPEN: July 13, 2015 at 10:30 AM

ADDENDUM # 1

TO ALL BIDDERS:
You are hereby notified of the following changes to the above mentioned bid:

The subject bid has been postponed until further notice.

Please sign, date and return this addendum with your bid to the Procurement Department, 1401 J.F.K Boulevard, Bid Room 170A, Philadelphia, PA 19102-1685 as it now becomes a part of the proposal.

Ken Owens
J. Manton, Buyer

For
Janice Manton

AUTHORIZED SIGNATURE

FIRM NAME (PRINT)

DATE

JM/dr

PROCUREMENT DEPARTMENT
Rm 120 Municipal Services Building
Philadelphia, PA 19102-1685
FAX: (215) 686-4716

CITY OF PHILADELPHIA

Mary E. Stitt
Procurement Commissioner

July 20, 2015

BID NUMBER: S6Z62190

TITLE: Boiler Service and Inspection,

DEPARTMENT: VARIOUS

DATE TO OPEN: July 13, 2015 at 10:30 AM

ADDENDUM # **2**

TO ALL BIDDERS:
You are hereby notified of the following changes to the above mentioned bid:

The subject bid is now scheduled to open on August 10, 2015 at 10:30 AM

Questions and Answers

Question 1. Section 5.1.1 Exhaust Gas Analyzers: The Exhaust Gas Analyzers are Auto Flame, not Power Flame as is listed, correct?

Answer1. Correct, they are manufactured by Autoflame. Under section 5.1.1 change Power Flame to Autoflame.

Question 2. Section 2.2.10 Yearly Calibration and Cleaning: The EGA or Exhaust Gas Analyzer are Auto Flame products that cannot be field calibrated according to the manufacturer. Auto Flame requires that the EGA units be removed and sent back to Auto Flame for calibration. Is this the intention of this section?

Answer 2. No. Follow the steps outlined 2.2.10.1 through 2.2.10.4

Question 3. Section 2.2.11 Boiler Valve Certification: Is there a schedule of how many and which of the safety valves needs to be re-certified each year?

Answer 3. Certify all safety relief valves once every year, as sited in ASME Boiler and Pressure Vessel Code 2010 Vol. VI, Appendix I, Exhibit C,. Sections IV and V.

Question 4. Section 5.1.2 Southwest Water Treatment Plant: The Units of measure should be LO (Lot), not YR, EA, & MO as listed, correct?

Answer 4. The units of measure for the Southwest location are correct as listed. .

Question 5. It is our understanding that some of the facilities have elected to do the Annual Cleaning of their boilers and other work covered in this contract with PWD personnel. Under this contract it will be **required** of the successful bidder to perform the Annual Cleaning and all other listed services of all listed boilers and burners, correct?

Answer 5. Not correct. As a requirement's contract, the City has the right to utilize the services on the contract resulting from this invitation and Bid, on an as needed basis or when it deems it necessary and beneficial to the city and/or the Water Department.

Please sign, date and return this addendum with your bid to the Procurement Department, 1401 J.F.K Boulevard, Bid Room 170A, Philadelphia, PA 19102-1685 as it now becomes a part of the proposal.

J. Manton, Buyer

AUTHORIZED SIGNATURE

FIRM NAME (PRINT)

DATE

JM/dr