

**PROCUREMENT DEPARTMENT**  
Rm 120 Municipal Services Building  
Philadelphia, PA 19102-1685  
FAX: (215) 686-4716

# CITY OF PHILADELPHIA

Hugh Ortman  
Procurement Commissioner

April 10, 2012

**BID NUMBER:** S2YQ6480  
**TITLE:** Air Conditioning Maintenance and Repairs  
**DEPARTMENT:** Various  
**DATE TO OPEN:** April 25, 2012 at 10:30 AM

## ADDENDUM # 1

### **TO ALL BIDDERS:**

**You are hereby notified of the following changes to the above mentioned bid:**

The following paragraph is hereby incorporated into Invitation and Bid #S2YQ6480.

#### 2.6.4

The successful vendor should be able to provide and maintain HVAC Auto-Detect, Auto Dial, and Remote Monitoring system for the Office of Innovation and Technology Data Center HVAC environment. In order for Data Center staff and HVAC vendor to take appropriate action to prevent damage, disruptions, and downtime, the monitoring system should detect changes 24 hours a day. The system should track the following critical environmental and operating conditions: temperature changes, power failures and surges, pressure, timers, alarms, excess humidity, water seepage, floods, water pump conditions, intrusion, and other conditions which would threaten the proper operation of the HVAC environment. The vendor should be able to configure the monitoring system to allow users to receive notification of problems and solicit reports from any location at any time, and should enable the monitoring system to provide real-time data and event logging to record information at specified intervals.

Please sign, date and return this addendum with your bid to the Procurement Department, 1401 J.F.K Boulevard, Bid Room 170A, Philadelphia, PA 19102-1685 as it now becomes a part of the proposal.

A. Campfield  
Buyer, A. Campfield

\_\_\_\_\_  
AUTHORIZED SIGNATURE

\_\_\_\_\_  
FIRM NAME (PRINT)

\_\_\_\_\_  
DATE

AC/sj