

PROCUREMENT DEPARTMENT
Rm 120 Municipal Services Building
Philadelphia, PA 19102-1685
FAX: (215) 686-4716

CITY OF PHILADELPHIA

Trevor Day
Procurement Commissioner

July 11, 2016

BID NUMBER: S7Z62000
TITLE: Emergency Electrical Generator Maintenance and Repair
DEPARTMENT: Various
DATE TO OPEN: July 20, 2016 at 10:30 AM

ADDENDUM # 1

TO ALL BIDDERS:

You are hereby notified of the following changes to the above mentioned bid:

The bid opening will be postponed to August 03, 2016 at 10:30 AM

1. The unit info for the City Commissioners Office (26052 001 010) is incorrect. Will you please provide the correct Generator Model Number and kW size.

The correct unit information (for item 5.13) is as follows:

26052 001 010

Annual Maintenance for City Commissioners Office
4700 Wissahickon Ave, Bldg F, Voting Machine Warehouse
Onan GGHD-4478463

2. Can you please provide a kW size for the unit at Torresdale FWPS # 1 (26052 020 019)

See table below.

3. Can you please provide a kW size for the unit at Torresdale FWPS # 2 (26052 020 020)

See table below.

4. Can you please provide a kW size for the unit at the Department of Public Health-Health Admin Building (26052 017 130)

See table below.

5. How many oil samples for analysis are we to pull during the year? The way it is written it reads to pull 4 times a year.

Oil sample analysis is required 4 times per year.


6. To check for the quality (specific gravity) of the fuel will require a fuel analysis to be pulled and send to a lab. Please let us know if you would like a fuel analysis pulled and sent to a lab.

Vendor is required to check fuel supply for quality (specific gravity). Any methods or procedures used to check fuel supply for quality (specific gravity) is to be determined by the vendor.

7. For information purposes only, see table below for additional KW information.

Item #	Commodity Code	KW
5.11	26052 020 015	500
5.12	26052 020 016	500
5.13	26052 001 010	100
5.16	26052 017 135	30
5.17	26052 017 077	350
5.19	26052 017 076	1000
5.20	26052 017 106	1000
5.21	26052 017 107	750
5.23	26052 017 124	100
5.25	26052 020 019	2500
5.26	26052 020 020	2500
5.28	26052 017 130	750
5.29	26052 023 000	25
5.30	26052 023 001	25
5.31	26052 023 002	25

Please sign, date and return this addendum with your bid to the Procurement Department, 1401 J.F.K Boulevard, Bid Room 170A, Philadelphia, PA 19102-1685 as it now becomes a part of the proposal.


S. Brown, Buyer

AUTHORIZED SIGNATURE

FIRM NAME (PRINT)

DATE

SB/ cw